



**TITAN DRILLING**

Document Name	HSE-FOR-8.1.1 Fire Extinguisher Checklist
Document ID	HSE-131
Version Date	14/03/2024
Version	1
Approved	HSM

FIRE EXTINGUISHERS MONTHLY CHECKLIST

YEAR:2025															COMMENTS
TYPE AND CAPACITY	LOCATION	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Checked by physical inspection for the following:	
														Fire Extinguishers	
														CORROSION or DAMAGE	
														SAFETY PIN IN PLACE	
														ANTI-TAMPER SEAL	
														PERISHED/BLOCKED HOSE	
														<u>Fire Hosereels</u>	
														LEAKING GLANDS or SEALS	
														PERISHED/BLOCKED HOSE	
														NOZZLE MISSING/BLOCKED	
														if all in good order,enter "ok"in	
														the appropriate space. If defects	
														are observed enter defect code	
														instead. Defective items must be	
														tagged "UNSAFE FOR USE" and	
														must be repaired promptly	
														<u>List of Defect Codes</u>	
														CD=Cylinder Damaged/Corrossion	
														HD=Hose Damaged	
														SP= Safety Pin or Seal Missing	
														DP=Depressuried	
														LK=leaking Gland or seal	
														NZ=Missing or blocked nozzle	
														OVD=Service date overdue	
														Fire CO-ORDINATOR TO INITIAL & DATE	
CHECKED BY: (initial)															
Date of inspection (initials and review date)															
Management over inspection (initials and review Date)															